COMMERCIAL HVAC INCENTIVE APPLICATION

Incentive agreements will only be processed if fully completed and signed. By signing below, customer and contractor agree to having met the Terms and Conditions. Once completed, return to your electric utility provider.

1. Customer Name: _____ Electric Utility: _____

Customer's Account #: _____ Tax ID #: _____

Customer's Mailing Address: _____ Telephone #: _____

Installation Address & City (if different from above): _____

Customer: _____ _____ _____

Print Name | Signature | Date

2. Contractor Name: _____

Address: _____ Telephone #: _____

Fax #: _____ E-mail: _____

Contractor: _____ _____ _____

Print Name | Signature | Date

☐ Completed W -9 Form attached

NOTE: *W-9 Form is needed for commercial and industrial applications; incentive will not be processed unless W-9 form is properly completed and attached.*

TERMS & CONDITIONS

This incentive program applies to air-conditioners and heat pumps in new or existing nonresidential and master-metered multifamily buildings.

PROOF OF PURCHASE: **Sales receipt(s) or invoice(s) itemizing the new equipment and indicating the size, type, make, model, purchase date, vendor name, and AHRI Certificate of Product Ratings must accompany each energy efficiency incentive application. If an AHRI Certificate is not available, provide mfr's product data showing equipment ratings at AHRI test conditions.**

INCENTIVE OFFER: This energy efficiency incentive program covers equipment during the program year in which it is purchased and installed. Details of this program, including incentive levels, are included in the program guidelines and are subject to change without notice. The electric utility reserves the right to limit incentives.

ELIGIBLE EQUIPMENT: Equipment must be new, permanently installed, and operational at the customer's facility. Equipment must meet the minimum efficiency levels as shown in Table 1, and must be rated at the most recent AHRI standards. Prior to submittal of application, the following must be completed on all equipment: air and water balancing, installation and calibration of control system, and training of customer's maintenance personnel.

ISSUING INCENTIVES: Equipment must be purchased and installed before an energy incentive is issued. Falsifying any information may lead to cancellation of this and future incentive applications, a claim by the electric utility for the return of any incentive, and/or referral for prosecution. Please allow 45 days for delivery of incentives. Submitting an application with incomplete or missing information may delay processing of the incentive.

APPROVAL & VERIFICATION: Incentives exceeding $5,000 require approval by the electric utility before purchase or installation. The utility reserves the right to verify sales transactions, review equipment specifications and inspect all projects prior to and after installation.

TAX LIABILITY: Neither the electric utility nor Nebraska Public Power District are responsible for any tax liability imposed on the customer as a result of the energy efficiency incentive.

ENDORSEMENT: Neither the electric utility nor Nebraska Public Power District endorses any particular manufacturers, products, or system designs in promoting this program. Equivalent products must be pre-approved by the electric utility and Nebraska Public Power District.

DISPOSAL: The customer/contractor is responsible for the proper disposal and/or recycling of any waste generated as a result of this project.

SAFETY & BUILDING CODES: The customer/contractor agrees that each measure complies with all federal, state, and local safety, building, and environmental codes. All products must be UL-listed and installed per manufacturer's instructions.

DISCLAIMER OF WARRANTIES: Neither the electric utility nor Nebraska Public Power District warrant the performance of any equipment either expressly or implicitly. Contact the supplier or contractor for details regarding equipment warranties.

ENERGY BENEFITS: The utility is entitled to 100% of the energy benefits associated with the implemented Energy Conservation Measure, excluding the value of energy cost savings realized by the Customer, but including all rights to all associated energy, capacity, reserves, and emissions. The Customer agrees to provide the Utility with such further documentation as the Utility may request to confirm the Utility's ownership of such benefits.

Table 1 - Eligible Equipment.

Unit Code[1]	Equipment Type[2] (Split or Package)	Size (tons)	Minimum Cooling Efficiency[3a,b]	Minimum Heating Efficiency[3a,b]	Incentive
AC1	Air Conditioner or VRF A/C (air cooled)	< 5.4	15.0 SEER	n/a	$50
AC2	Air Conditioner or VRF A/C (air cooled)	< 5.4	16.0+ SEER	n/a	$150
AC3	Air Conditioner (air cooled)	≥ 5.4 to ≤ 20	14.0 IEER	n/a	$20/ton
AC4	VRF Air Conditioner (air cooled)	≥ 5.4 to ≤ 20	18.0 IEER	n/a	$30/ton
AS1	Air Source Heat Pump or VRF	< 5.4	15.0 SEER	8.5 HSPF	$100
AS2	Air Source Heat Pump or VRF	< 5.4	16.0+ SEER	8.5 HSPF	$300
AS3	Air Source Heat Pump	≥ 5.4 to ≤ 20	12.5 IEER	3.2 @ 47°F	$40/ton
AS4	VRF Air Source Heat Pump	≥ 5.4 to ≤ 20	18.0 IEER	3.2 @ 47°F	$50/ton
WLHP1	Water Source Heat Pump or VRF	< 1.4	11.2 @ 86°F	3.9 @ 68°F	$100/ton
WLHP2	Water Source Heat Pump or VRF	≥ 1.4 to ≤ 20	12.0 @ 86°F	3.9 @ 68°F	$100/ton
GWHP	Open Loop Ground Source HP or VRF	Any	16.2 @ 59°F	3.5 @ 50°F	$220/ton
GLHP	Closed Loop Ground Source HP or VRF	Any	13.4 @ 77°F	2.8 @ 32°F	$220/ton
WWLHP	Water-to-Water HP (water loop)	≤ 20	10.6 @ 86°F	3.7 @ 68°F	$100/ton
WGWHP	Water-to-Water HP (groundwater source)	Any	16.3 @ 59°F	3.1 @ 50°F	$220/ton
WGLHP	Water-to-Water HP (ground source)	Any	12.1 @ 77°F	2.5 @ 32°F	$220/ton

[1]WLHP - Water Source Heat Pump (typically boiler/cooling tower applications); GWHP - Groundwater Heat Pump (typically open loop system); GLHP - Ground Source Heat Pump (typically earth or pond coupled); VRF - Variable Refrigerant Flow.

[2] Table implies new matched indoor and outdoor components. If different, contact your electric utility.

[3a] Unless noted otherwise, all cooling ratings are EERs, and all heating ratings are C.O.P.s. VRF ratings are for non-ducted equipment, however, actual installed configuration may be ducted, non-ducted, or mixed.

[3b] Equipment efficiencies are full load ratings (except for VRF and IEER rated equipment) according to test procedures and conditions specified in ASHRAE Standard 90.1 - Energy Standard for Buildings Except Low-Rise Residential Buildings, and the following standards as applicable: AHRI/ISO 13256-1 - Water-to-Air and Brine-to-Air Heat Pumps, AHRI/ISO 13256-2 - Water-to-Water and Brine-to-Water Heat Pumps, and ANSI/AHRI Standard 1230 - Performance Rating of Variable Refrigerant Flow Multi-Split Air-Conditioning and Heat Pump Equipment.

Installing Contractor: Complete the following information. (Two example entries are shown.)

Unit Code	(A) Qty	Manufacturer & Model No.	(B) Size (Tons)	Cooling Effic. *	Heating Effic. *	(C) Incentive per Table 1	Incentive A x B x C (Note: Multiply by B only if incentive is per ton)
AC3	3	A/C Mfg 48DX015	15	14.7 IEER	n/a	$20/ton	3 x 15 x $20 = $900
AS1	4	ABC Mft TWA042, TTC042	3.5	15.8 SEER	9.0 HSPF	$100	4 x $100 = $400

EXAMPLE

* Cooling Efficiency and Heating Efficiency must be listed at the temperature rating shown in Table 1.

Total Incentive: _____